

- KEYED NOTES**
- ① DUCT, ON ROOF, TO BE REMOVED.
 - ② MAKE-UP AIR UNIT TO BE REMOVED FOR RELOCATION.
 - ③ REFRIGERANT PIPING, ON ROOF, TO BE REMOVED INCLUDING SUPPORTS, ETC.
 - ④ REFRIGERANT PIPING, DOWN WALL & TO CONDENSING UNITS TO BE REMOVED INCLUDING SUPPORTS, TRIM, ETC.
 - ⑤ CONDENSING UNITS TO REMAIN.
 - ⑥ EXHAUST FAN TO BE REMOVED INCLUDING ASSOCIATED DUCT, LOUVER, CONTROLS, THERMOSTAT, ETC. FAN AND ALL ASSOCIATED ITEMS ARE TO BE STORED FOR REINSTALLATION.
 - ⑦ DUCT TO REMAIN. PROVIDE TEMPORARY CAP/SEAL OF DUCT DURING CONSTRUCTION.
 - ⑧ LOUVER WITH ASSOCIATED DUCT, DAMPER, ETC. TO BE REMOVED & STORED FOR REINSTALLATION.
 - ⑨ UNIT HEATER WITH ASSOCIATED HANGERS, DUCT, LOUVER TO BE REMOVED AND STORED FOR REINSTALLATION.
 - ⑩ DUCT/EXTERIOR WALL PENETRATION WITH DUCT REMOVED; INFILL WALL WITH STRUCTURAL STEEL STUD FRAMING, EXTERIOR METAL WALL PANELS (TO MATCH EXISTING PANELS) & MINIMUM 6" THK WALL INSULATION WITH INTERIOR WALL COVERING TO MATCH EXISTING SURROUNDING SURFACES.
 - ⑪ CONDENSING UNIT TO BE RELOCATED.


1 MECHANICAL DEMOLITION FLOOR PLAN
 M2.01 SCALE: 1/8" = 1'-0"

BASE BID
 ALL WORK ASSOCIATED WITH MAKE-UP AIR UNITS MAU-E35A & MAU-E35B AND CONDENSING UNITS CU-E35A & CU-E35B SHALL BE DELETED. DELETE KEYED NOTES 1,2,3,4,10 & 11.

ALTERNATE #1
 ALL WORK ASSOCIATED WITH MAKE-UP AIR UNITS MAU-E35A & MAU-E35B AND CONDENSING UNITS CU-E35A & CU-E35B SHALL BE PART OF ALTERNATE #1.

DHO ENGINEERING
 Telephone: 405-947-6524
 Facsimile: 405-947-0472
 3629 NORTHWEST 24th STREET
 OKLAHOMA CITY, OK 73107
 OK Cert. of Auth. No. 3955
 Expiration 06/30/12

ARCHITECTURE
 ARCHITECTURE
 INTERIORS
 PLANNING
 STUDIO ARCHITECTURE
 1112 NORTH WALKER
 OKLAHOMA CITY, OK 73103
 VOICE: 405.605.1044
 FACSIMILE: 405.606.7044
 WWW.STUDIOARC.COM



ARCHITECTURE:
 Studio Architecture, P.C.
 Tel: 405.605.1044
 Fax: 405.606.7044

STRUCTURAL:
 Wallace Engineering
 Tel: 918.584.5858
 Fax: 918.584.8689

MECHANICAL & PLUMBING:
 DHO Engineering
 Tel: 405.947.8524
 Fax: 405.947.0472

ELECTRICAL:
 Horner Associate Engineering
 Tel: 405.801.2528
 Fax: 405.801.2529

CLAREMORE CIVIC EXPO CENTER
 SHOP REPLACEMENT
 CLAREMORE, OKLAHOMA

Revision	MECHANICAL DEMOLITION FLOOR PLAN
Project Number	11 019
Sheet Title	
Date	12/9/2011
Sheet No.	M2.01