

PROJECT ADDENDUM

| Bid / RFP / RFQ Number: | SB-2022-18 | |
|-------------------------|-------------------------------|--|
| Project Number: | E2022-011 | |
| Project Name: | FY – 2022/2023 Street Repairs | |
| Addendum No.: | 1 | |
| Date of Addendum: | January 19, 2023 | |

To All Plan Holders:

Please note the following changes and/or clarifications:

1. BID OPENING DATE EXTENSION:

The bid date has been revised to open: <u>JANUARY 27TH @ 10:00am</u>. Bid Opening location to remain the same.

2. S4 SUPERPAVE SURFACE COURSE:

Per ODOT 2019 Standard Specifications – 708.04 COMPOSITION OF MIXTURES – C. RECLAIMED ASPHALT PAVEMENT (RAP): Mixtures for surface layer SHALL NOT contain RAP. Other layers may include RAP as noted in Table 708.5.

3. CONCRETE DRIVEWAY APRON EXCAVATION:

Pay Quantity Note #13 "Concrete Driveway Apron (HES)": All excavation and/or undercut required (for placement of aggregate base or removal of unsuitable material) shall be considered incidental to this pay item and NOT included in the Unclassified Excavation Pay Item (#9), as referenced in the Pay Item #13.

All other terms, conditions and specifications remain unchanged. Any additions made to the Bidding and Contract Documents including the Plans and Specifications per this Addendum shall be considered a part of the original Bidding and Contract Documents. The professional seals and signatures applied to the original Bidding and Contract Documents are thereby considered to cover any additions to said documents per this Addendum.



Levi P. Hix, P.E. Engineering Project Manager 1/19/23

Date

Bidders shall acknowledge receipt of this Addendum in the space provided in the Bid Proposal Form.